



Market Redefinition: Accreditation Reform

Resource Adequacy Subcommittee

January 18, 2023

Purpose & Key Takeaways



Purpose: Share 2023 work plan based on recent stakeholder feedback and provide further education and discussion on the Direct-Loss of Load (Direct-LOL) method

Key Takeaways:

- MISO provided its recommendation at the Nov 2022 RASC to use the Direct-LOL for wind and solar accreditation
- In the first half of 2023, MISO will evaluate the extension of the Direct-LOL method to non-emergency resources as well as other design elements critical to the PRM calculation
- Detailed design discussions for wind/solar accreditation will resume in Q3 2023
- MISO is targeting a filing for RA accreditation reforms in Q4 2023

The goal of today's discussion is to share detailed recommendations for accreditation

FRAME the issue; set guiding parameters for this year's effort

- ✓ Define the problem statement, scope and key considerations

EVALUATE three broad categories of accreditation approaches for wind and solar resources

- ✓ Define a set of evaluation criteria
- ✓ Select a representative set of three diverse future portfolios in pursuit of a least regrets approach
- ✓ Mine historic data where available; simulate data for emerging technologies and future portfolios
- ✓ Identify periods of high risk under different generation portfolios
- ✓ Evaluate how variations of the three accreditation approaches capture the periods of high risk
- ✓ Apply evaluation criteria to the results
- ✓ Narrow to one general approach for refinement in the design phase

DESIGN the proposed solution showing how the accreditation method would work

- ✓ Discuss and determine key design attributes
- ✓ Pursue proof of concept and straw proposal
- ✓ Perform impact analysis using today's resource portfolio
- ☐ Refine proposal with stakeholder input

We are here

Reminder of the problem statement and scope developed by MISO and stakeholders to guide this effort:

Problem Statement

Resource accreditation should reflect the availability of resources when they are most needed. Significant growth of variable, energy-limited resources in the MISO footprint, along with changing weather impacts and operational practices, are shifting risk profiles in highly dynamic ways with implications to Resource Adequacy and planning. MISO's existing accreditation methods for non-thermal resources require further evaluation to ensure that the accredited capacity value reflects the capability and availability of the resource during the periods of highest reliability risk.

Scope

Revisit the established accreditation practices for non-thermal resources with a priority focus on those with the greatest reliability impact in the near-term.

Wind and Solar Accreditation

MISO's 2023 work on non-thermal accreditation will be focused on addressing stakeholder concerns shared in recent feedback

1. Evaluation of extending Direct-LOL recommendation to all non-emergency resources

2. Determine a way to shift PRM allocation from co-incident load peak to co-incident risk peak (i.e. LOL hours, gross load vs net load, etc.)

File comprehensive resource adequacy accreditation reforms at FERC
(Implementation TBD after PY 24-25)

Q1/Q2

Q3

Q4


Detailed design discussions and engagement with stakeholders

Based on stakeholder feedback, MISO proposes a strawman to be refined over the course of 2023


1. Adjust accreditation for all non-emergency resources (coal, gas, nuclear, wind, solar, storage, hydro, etc.) to the proposal laid out at the Nov. 30 RASC (and being discussed again today)
 - For current Schedule-53 resources this means adjusting the definition of UCAP from EFORd based to Direct-LOL based
2. Adjust process to calculate LSEs PRMR based on MISO's coincident LOL-hours rather than coincident peak load hours

MISO recommends separately accrediting wind and solar resources based on performance during RA Hours and adjusting unit accreditation to a class capacity value that is derived from the Direct-LOL method


Existing Approach for Wind 




Existing Approach for Solar 



Recommended Approach for Wind 



Recommended Approach for Solar 



1

Calculate the simulated availability of wind and solar resources during loss of load hours – i.e. Direct-LOL (Loss of Load) measurement

STEP 1

Calculate average availability during LOL hours

1.1. Extract Loss of Load (LOL) hours and generator availability by unit/sample/weather year

1.2. For each sample take a generator's availability during LOL hours and average the output

STEP 2

Aggregate to class-level

2.1. Sum the average generator availability during LOL hours for the entire resource class

2.2. Sum the installed capacities (ICAP) of the generators for the entire resource class

STEP 3

Calculate wind and solar class-level UCAP

3. Divide the outcomes of Step 2.1 by Step 2.2

Example: Illustrative direct-LOL accreditation calculation for solar

LOLE
Study
Model

(used to
set the
PRMR)

Outputs
(LOL, EUE,
Generation)

System Unserved Energy

Hour of Year	Weather Year 1			Weather Year 2		
	Sample 1	Sample 2	Sample N	Sample 1	Sample 2	Sample N
1	0	0	0	10	0	0
2	0	0	0	0	0	0
3	0	0	0	0	0	0
4	20	0	0	0	0	0
5	40	0	0	0	30	0
6	10	0	0	0	10	0
7	0	0	0	0	5	0
8	0	0	0	0	2	0
9	0	0	0	0	1	0
10	0	0	0	0	0	0
...	0	0	6	0	0	0
8758	0	0	10	0	0	0
8759	0	0	2	0	0	0
8760	0	0	0	0	0	0

Two weather years, 6 outage samples

LOLE = 0.67 days/year

LOLH = 2 hours/year

EUE = 24.3 MWh/year

Generator Availability*

(installed capacity = 10 MW)

Hour of Year	Weather Year 1			Weather Year 2		
	Sample 1	Sample 2	Sample N	Sample 1	Sample 2	Sample N
1	0	0	0	0	0	0
2	0	0	0	0	0	0
3	1	1	1	0	0	0
4	4	4	4	2	2	2
5	8	8	8	3	3	3
6	3	3	3	1	1	1
7	1	1	1	0	0	0
8	0	0	0	0	0	0
9	0	0	0	0	0	0
10	1	1	1	2	2	2
...	5	5	5	6	6	6
8758	10	10	10	0	0	0
8759	6	6	6	6	6	6
8760	3	3	3	1	1	1


Average output during events = 3.33 MW

Nameplate Capacity = 10 MW

Capacity Accreditation = 33%

2

MISO recommends directly measuring resource availability against operational need to set unit level accreditation – Same as thermal



Summary of the total number of loss of load (LOL) hours per season by Planning Year

- In the evaluation/design models, MISO used 1,100 *samples**
- In the full implementation we will use 18,750 *samples**
- The table shows the total number of LOL hours from the latest LOLE model (PY23-24)
 - The PY22-23 shows the seasonal breakdown of LOL hours using the adjusted seasonal LOLE targets
- MISO plans to do full testing and evaluation of LOL hours before making final decisions and preparing a filing

Season	Seasonal LOLE Target (Days/year)	Seasonal loss of load (LOL) hours
Fall	0.01	477
Spring	0.01	82
Summer	0.1	5,450
Winter	0.01	1,137
Total	0.13	7,146

Discussion related to these Design elements will resume at the RASC in Q3 2023

Design Consideration	Direct LOL Accreditation Proposal	Rationale
Real time offers considered	5-minute Real Time Injection + (Forecast -dispatch instruction) over 3 years*	Measurement of wind/solar availability
Classes	Create separate classes for thermal, wind and solar	Creating separate classes by similarly performing resources will negate the impact mis-aligned RA hours
RA Hours calculation	Unchanged	Creating separate classes of similarly performing resources will negate the impact of mis-aligned RA hours
Region specific sub-classes	MISO wide to start; Additional analysis is needed to define smaller regions	Regional sub-classes can shift over time depending on the performance of resources within a class
Number of weather years	Align with PRM/LOLE model assumptions	Use same assumptions for simplicity and comparability

Next Steps

- Evaluate applicability of Direct-LOL method to all non-emergency resources (coal, gas, nuclear, wind, solar, storage, hydro, etc.)
- Evaluate if any other changes are needed for accreditation and conduct reconciliation with other processes to see if they should be modified
 - LOL or tight margin hours
 - Planning Reserve Margin Requirement (PRMR) allocation
 - Resource class definitions
 - Sub-class region definitions



Contact Information

Davey Lopez: dlopez@misoenergy.org

Jordan Bakke: jbakke@misoenergy.org

Appendix

Reminder of the criteria under which MISO is using for its recommendation

Impact

- Ability to identify and sufficiently mitigate actual risk under current and future portfolios and grid conditions, in conjunction with markets and operations
- Ensure sufficient capacity in the planning horizon when needed to maintain reliability
- Results in comparable outcomes with methods for other technology types or resource classes

Feasibility

- Relative practicality/ scalability/ administrative feasibility of implementation for both MISO and Market Participants
- Understandability for both MISO and Market Participants

Flexibility

- Ability to accommodate evolving resource portfolio and technologies that can help mitigate shifting risks across all time periods

Stability

- Ability to reasonably inform state and utility long-term resource planning processes which rely on accreditation

Direct-LOL accreditation offers distinct benefits over the existing accreditation practices for wind and solar resources




Method	Unit-Level	Class-Level	Impact	Flexibility	Feasibility	Stability
MISO's current Wind method	Performance during <i>peak hours</i>	<i>Average Individual-ELCC</i>	Aligns availability with need for class only, but not "actual" need	Extending to many other resource types misses synergistic effects	Computationally difficult, and hard to understand as method scales	Results averaged over a range; doesn't inform the future as well
MISO's current Solar method	Performance during <i>peak hours</i>	N/A	Doesn't align changing needs with availability	Easily extendable to other resource types	Computationally efficient, and easy to administer	Easy to predict, but doesn't reflect changing conditions
Wind/solar recommendation	<i>Seasonal RA Hours</i>	<i>Direct-LOL based Unforced Capacity (UCAP)</i>	Aligns availability and "actual" need*; Aligns with probabilistic and operational performance	Easily extendable to other resource types; accounts for synergistic effects; comparable to thermal	Computationally efficient, and easy to administer	Results dependent on resource mix; informs the future well
MISO's Thermal Method (Reference)	<i>Seasonal RA Hours</i>	<i>EFORD based Unforced Capacity (UCAP)</i>				

*Actual for D-LOL = simulated conditions of the current system. See appendix.

Direct-LOL additional example

Total Wind ICAP: 90 MW					
Weather				# of Samples	Total Wind
Year	Month	Day	Hour	with LOL	Generation (MW)
2016	July	28	1	0	90
2016	July	28	2	0	85
2016	July	28	3	0	80
2016	July	28	4	0	70
2016	July	28	5	0	65
2016	July	28	6	0	60
2016	July	28	7	0	50
2016	July	28	8	0	48
2016	July	28	9	0	45
2016	July	28	10	0	44
2016	July	28	11	0	35
2016	July	28	12	0	30
2016	July	28	13	0	25
2016	July	28	14	1	16
2016	July	28	15	8	12
2016	July	28	16	5	9
2016	July	28	17	2	7
2016	July	28	18	1	7
2016	July	28	19	0	15
2016	July	28	20	0	20
2016	July	28	21	0	35
2016	July	28	22	0	40
2016	July	28	23	0	50
2016	July	28	24	0	60




$$\text{Direct LOL Reliability Contribution (\%)} = \frac{\text{Weighted Average Availability (MW) During LOL Hours}}{\text{ICAP (MW)}}$$

$$\text{Direct LOL Reliability Contribution (\%)} = \frac{(1 * 16) + (8 * 12) + (5 * 9) + (2 * 7) + (1 * 7)}{17 \text{ LOL Samples}} = 10.5$$

$$\text{Direct LOL Reliability Contribution (\%)} = \frac{10.5 \text{ (MW)}}{90 \text{ (MW)}} = 11.7\%$$


Direct-LOL replaces the calculation of UCAP for non-thermal resources, but the rest of the process remains unchanged



Direct-LOL results using latest Planning Year (PY), results from the non-thermal evaluation and the 2022 Regional Resource Assessment (RRA) portfolios



Utility-scale Solar



Utility-scale Wind

