



LRTP Tranche 2.1

Benefits Analysis Results Review

September 25, 2024

Purpose & Key Takeaways



Purpose


Continue discussion of LRTP Tranche 2.1 benefit analysis results

Key Takeaways

- Updated \$21.8B portfolio costs reflect further refinements of the estimated facility costs
- F2A benefits also refined further with updates to mitigation of reliability issues, avoided capacity costs, capacity savings from reduced losses, and avoided transmission metrics
- Benefits reflect a broad set of metrics to show a regional benefit-to-cost ratio of at least 1.8 over the first 20 years of transmission in-service life using Future 2A
- Future 1A results also show a B/C ratio greater than 1.0 for the Midwest Subregion


The Tranche 2.1 portfolio enables the resources required to maintain reliability and serve energy needs for the MISO system while providing benefits in excess of its cost

- Selected projects represent least-regrets solutions to ensure reliable and efficient energy delivery to MISO Midwest customers




L RTP Tranche 2.1 estimated
project cost = \$21.8B (2024\$)*
*as of 9/19/2024


Tranche 2.1 portfolio under Future 2A provides a regional benefit-to-cost ratio of at least 1.8 capturing multiple types of reliability, economic and policy value



Tranche 2.1 portfolio benefits exceed costs and are broadly distributed across the Midwest Subregion with each zone showing a B/C ratio > 1.0* under Future 2A



Map of Midwest Cost Allocation Zone Boundaries*



*MISO Tariff, Attachment WW


Avoided Capacity Costs

Avoided Capacity Costs reflect more efficient buildout of resources where transmission expansion improves access to resources across the footprint

- Transmission constraints limit the ability for regional resources to meet the capacity needs of the MISO region
- LRTP projects increase the capacity of transmission system and allow the capacity needs of the MISO region to be met with fewer resources
 - This is calculated by measuring zonal transmission limits with and without LRTP
- Benefits examine the difference in the additional capacity reserves that are needed to maintain 0.1d/yr LOLE with and without LRTP
- Incremental EGEAS resource expansion is performed with the additional capacity reserves to determine the capital costs for resource additions

The Avoided Capacity Cost (ACC) metric reflects the capital cost savings from the increase in transmission capability provided by LRTP, enabling access to resources over the wider MISO footprint

- This benefit leverages LOLE modeling and incorporates a simplified representation of transmission constraints
- The benefit assesses the change in loss of load expectation (LOLE) to determine the adjustment in planning reserves to meet the LOLE target with and without the LRTP portfolio
- Change in planning reserve is applied to the base PRM value used in EGEAS to determine the amount and composition of the additional resources that would be needed in the absence of LRTP



LOLE modeling will be used to determine the adjustment in the capacity required to meet the LOLE target with and without the LRTP portfolio

LOLE Models: F2A & F1A, 2042

EGEAS Expansion for Avoided Capacity Cost + Capacity Savings from Reduced Losses Benefit Metrics

LOLE model based on Futures 1A & 2A generation expansions

- Multiple weather years
- Multiple outage patterns
- Hourly granularity

Explicit modeling of zonal transmission in LOLE model

Calculate reserve requirement w/o LRTP
(base zonal transmission)

Calculate reserve requirement w/ LRTP
(base zonal transmission + Tranche 2)

Calculate reserve requirement increase without Tranche 2.1 for F2A & F1A, 2042

From 2042 value, calculate reserve requirement phase-in for F2A & F1A and add to CSRL reserve requirement values

Include original expansions & Flex as Committed for F2A & F1A

Rerun F2A, F1A EGEAS models with combined reserve requirement values and Committed buildout + Flex capacity

Calculate total additional capacity cost over 20 years

Calculate ACC benefit in proportion to its reserve requirement contribution

Calculate 20-year present value of ACC benefit

LOLE – Loss of Load Expectation

Base zonal and (Base zonal + Tranche 2.1) transmission was determined using a transfer analysis.


PRM value will be assumed to increase over the last 10 years of the study period

- PRM is assumed constant until Tranche 2.1 projects come into service in 2032, and then increases as the expansions proceed to 2042
- Difference in PRM between the base and Tranche 2.1 cases will be added to the original 18% PRM assumption
- PRM change from base to Tranche 2.1 case calculated for 2042
- PRM change assumed to increase linearly from 2032 until 2042
- The total capacity addition is split into benefit components by the percent contribution to the additional PRM value

Combined ACC+CSRL PRM Phase-In					Avoided Capacity Costs (ACC)		Capacity Savings from Reduced Losses (CSRL)	
			Total	Total				
			PRM Enforced (%)	PRM Addition (%)	% Contribution to Total Additional PRM, 2042:			
Year	1	2023	18.05		90%		10%	
	2	2024	18.05					
	3	2025	18.05					
	4	2026	18.05		ACC		CSRL	
	5	2027	18.05		2032-2041 values extrapolated		Interim values interpolated	
	6	2028	18.05		from 2042 value		from 2032, 2042 values	
	7	2029	18.05					
	8	2030	18.05		Additional PRM (%) from CIL/CEL:		Additional PRM (%) from reduced losses:	
	9	2031	18.05					
Year	10	2032	19.66	1.61	0.80	2032	0.81	
	11	2033	20.47	2.42	1.59	2033	0.83	
	12	2034	21.28	3.23	2.39	2034	0.84	
	13	2035	22.10	4.05	3.19	2035	0.86	
	14	2036	22.91	4.86	3.98	2036	0.88	
	15	2037	23.72	5.67	4.78	2037	0.90	
	16	2038	24.54	6.49	5.57	2038	0.91	
	17	2039	25.35	7.30	6.37	2039	0.93	
	18	2040	26.17	8.12	7.17	2040	0.95	
	19	2041	26.98	8.93	7.96	2041	0.97	
Year	20	2042	27.81	9.76	8.76	2042	1	

Tranche 2.1 portfolio improves transmission capacity to provide more efficient resource investment

- LRTP Tranche 2.1 enables access to regional resources, which reduces the need additional capacity investment
- LRTP Tranche 2.1 avoids the need for 22.8GW of capacity in addition to F2A resources and provides a 20-year present value benefit of \$16.3B*



Mitigation of Reliability Issues

Reliability benefits reflect the value of mitigating risk of unserved load with transmission investment

- System performance requirements are established by planning criteria and industry standards to reduce risk of unserved load (e. g., planning standards, storm hardening criteria)
- Specific thermal and voltage criteria are defined for acceptable system performance
- Failure to mitigate violations of thermal/voltage criteria can result in unserved load
- Transmission solutions alleviate thermal/and voltage violations to mitigate risk of unserved load
- Reliability benefits can be quantified using the avoided risk of unserved load that reflects the value of uninterrupted service for customers

Reliability benefits monetize the avoided risk of unserved load that would otherwise occur if system performance criteria are not met

- Reliability benefits are provided by addressing thermal violations
 - Contingency violations must be addressed proactively – cannot rely on post-contingent action to fix an issue
 - Benefit analysis focuses on a narrow set of conditions:
 - Constraints caused by a single element (NERC Category P1, P2, P7) contingency¹
 - Mitigated by the LRTP portfolio, and
 - That cannot be mitigated by generation redispatch
- Reliability benefit can be measured by examining the amount of load shedding otherwise required to alleviate violations
 - The amount of load shedding that is avoided by LRTP projects is the reliability benefit of mitigating reliability issues
 - VOLL is established as a market price of energy that customers are willing to pay to avoid interruption of load and used to monetize benefit

$$\text{Benefit} = \text{LoadShedMW} \times \text{hrs} \times \text{VOLL}$$

where hrs = # risk hours represented by study case

$$\text{VOLL} = \text{range}(\$3,500/\text{MWh}^2, \$10,000/\text{MWh}^3)$$

¹[NERC TPL-001-5.1 Transmission Planning Standard](#),


²Current VOLL

³[Continued Reforms to Improve Scarcity Pricing and Price Formation \(MSC-2019-1\)](#)

Study scenarios represent conditions over multiple hours of the year and are used to examine and quantify load shedding risk

Hours of unserved load are determined by examining the dispatch and load distribution associated with each model scenario


- Model scenarios represent a subset of annual conditions
- Load shedding risk hours correspond to hours represented by the study scenario in the annual load distribution



A two-step process is used to perform reliability re-dispatch to mitigate issues and identify residual overloading that would require load shedding

- Generation re-dispatch
 - Applied to NERC Category P1, P2, and P7 contingencies as pre-contingent mitigation
 - Used primarily to recognize that renewable availability varies over the hours represented by the study model
 - Dispatch scenarios represent hours where renewable availability is higher or lower than reflected in study model
 - Renewable resources allowed to dispatch up for hours with excess availability
 - Renewables resources are limited to dispatch downward for hours without excess availability
 - Thermal resources participate in NERC Category P1 scenarios for consistency with production cost simulations (limitations are applied in Category P2 and P7)
- Load re-dispatch
 - Load re-dispatch is applied only to constraints that remain after generation re-dispatch
 - Used to calculate the amount of load reduction required to mitigate unresolved constraints
 - Corrective load shedding is applied in analysis to optimize load shedding for each contingency
 - Avoided load shedding for each scenario is the sum of the maximum amount of load reduction at each bus for all contingencies

Generation re-dispatch and load re-dispatch are used to identify load shedding risk



Example Calculation (illustrative)

Model	Redispatch Scenario	Monitored	Contingency	Pre-overload %	Pre-MW Relief Required	Buses	Sum of Max Load Shed MW	Scenario Hours	MWh Benefit
2032sum	up/down	St A- St B	P1_Ctg1	115%	16MW	bus-a bus-b	124	48	5,952
2032avg	up/down	St C - St D	P1_Ctg2	124%	32MW	bus-c bus-d bus-e	46	420	19,320
2032avg	down-only	St E - St F	P1_Ctg3	107%	20MW	bus-f bus-g bus-h bus-i	295	1362	401,790
2032avg	down-only	St G - St H	P2_Ctg4	109%	18MW				
							Load Shedding MWh		427,062

Reliability benefits monetize the avoided risk of unserved load that would otherwise occur if system performance criteria are not met


L RTP Tranche 2.1 projects address numerous thermal overloads that otherwise present a risk of unserved energy

Benefits

Total unserved energy risk by season (GWh)


	Summer	winter	average	light load
2032	449	58	2971	278
2042	149	80	400	115

L RTP Tranche 2.1 portfolio mitigates risk of unserved load from transmission overloading and yields 20-year present value benefits of \$14.8B




Future F1A Benefit Analysis Results


Tranche 2.1 portfolio also shows total benefits in excess of costs under the more conservative lower bookend of F1A



Under F1A the Tranche 2.1 portfolio continues to show benefits are broadly distributed across the Midwest Subregion with each zone showing at least a 1.0 B/C ratio



**Map of Midwest Cost Allocation Zone
Boundaries***



*MISO Tariff, Attachment WW


Congestion and Fuel Savings Natural Gas Price Sensitivity

MISO Futures used for the LRTP T2.1 study utilized new natural gas price forecast methodology

- Gas Pipeline Competition Model (GPCM) was used to develop forecasts instead of locked-down Henry Hub (HH) and blend of three different forecasts
- Use on base forecast gas price in EGEAS for all Futures
- Using the same assumptions, but referencing PROMOD output, create Future-specific and area-specific gas prices for use in PROMOD models
- A range of gas prices tested on LRTP Reference and Change Case PROMOD models was developed by evaluating historical HH gas prices spanning a 10-year period between 2012-2022




Future 2A Natural Gas prices were increased by 20 – 60% for sensitivity evaluation



- When comparing to HH prices a 20% increase was found to facilitate a starting point, which ensures year 2042 average price is on par with historical averages without 2042 max price overly exceeding historical high prices.
- When comparing HH prices a 60% increase was found to facilitate an end point, to create a year 2042 price that represented HH sale price that did not exceed historical highs (2005 and 2008) but instead represented price peaks between years 2012 to 2022

L RTP T2.1 transmission will provide greater congestion and fuel savings as natural gas price increases



- 20% gas price increase generates a \$9.1B congestion and fuel savings, approximately \$1B increase in savings
- 60% gas price increase generates a \$10.8B congestion and fuel savings increase, approximately \$2.6B increase in savings

Economic Development Impact from Transmission

Tranche 2.1 transmission investments will deliver significant economic development benefits to local economies in the MISO region

- Long-run impacts on economic growth are difficult to quantify, but short-run impacts on employment and economic output can be quantified
- MISO literature review on the impacts of transmission investment finds that every \$1 million in transmission investment powers:
 - 1 – 3 direct local jobs
 - 2 – 6 total local jobs
 - \$0.2 – \$1.1 million in total local economic output
- Ranges chosen to cover roughly 90% of study estimates found in literature review
- Direct jobs are high-quality jobs, with wages estimated to be about 30% higher than a typical worker's wages

Tranche 2.1 transmission investments are estimated to power between 22,000 and 65,000 direct jobs and between \$4 and \$24 billion in total economic output

	Tranche 2.1 Investment (\$Mns)	Direct Local Jobs		Total Local Jobs		Local Investment/Total Economic Output (\$Mns)	
<i>Central</i>		<i>Low Estimate</i>	<i>High Estimate</i>	<i>Low Estimate</i>	<i>High Estimate</i>	<i>Low Estimate</i>	<i>High Estimate</i>
MO	\$872	872	2,616	1,744	5,231	\$ 174	\$ 959
IL	\$2,886	2,886	8,659	5,772	17,317	\$ 577	\$ 3,175
IN	\$2,378	2,378	7,135	4,757	14,270	\$ 476	\$ 2,616
KY	\$77	77	230	153	459	\$ 15	\$ 84
<i>East</i>							
MI	\$2,672	2,672	8,015	5,344	16,031	\$ 534	\$ 2,939
<i>West</i>							
IA	\$3,606	3,606	10,817	7,212	21,635	\$ 721	\$ 3,966
MN	\$4,342	4,342	13,026	8,684	26,051	\$ 868	\$ 4,776
ND	\$188	188	564	376	1,129	\$ 38	\$ 207
SD	\$724	724	2,171	1,447	4,341	\$ 145	\$ 796
WI	\$4,086	4,086	12,257	8,171	24,514	\$ 817	\$ 4,494
Total	\$21,830	21,830	65,489	43,659	130,978	\$ 4,366	\$ 24,013

Questions?

LRTP Website

[Long Range Transmission Planning \(misoenergy.org\)](https://misoenergy.org)

LRTP Help Center

[Help Center \(misoenergy.org\)](https://misoenergy.org)

Appendix

MISO's approach to the Tranche 2.1 business case analysis builds off the Tranche 1 benefit metrics*


Benefit Metric	Description
1) Mitigation of reliability issues	Value of alleviating reliability issues that unresolved introduce a risk of unserved load
2) Reduced risks from extreme weather events	Increases grid resilience and decreases the probability of major service interruptions
3) Avoided capacity costs	Avoids capital costs for local resource builds versus regional expansions defined in Futures
4) Capacity Savings from Reduced Losses	Value of reducing transmission losses during peak capacity periods
5) Avoided transmission investments	Avoids the need for facility replacement due to age and condition
6) Congestion and fuel savings	Enhances market efficiency and provides access to low-cost generation
7) Energy Savings from Reduced Losses	Lower production costs to serve load with transmission facilities that reduce system losses
8) Reduced transmission outage costs	Reduced transmission congestion during forced and planning transmission outages
9) Decarbonization	Enables the economical dispatch of renewable resources to help reduce the carbon footprint

Common assumptions/variables used for evaluation of benefits

- Project recommendation is based on analysis of benefits over the 20-year time horizon starting with the assumed in-service date of the projects (2032)
- Benefits are also calculated for the 40-year time horizon to show potential value over the longer-term as projects will continue to be in-service
- Benefit cost analysis applies a discount rate of 7.1% which reflects the transmission owner weighted average cost of capital for transmission investments
- Additional analysis is performed using a discount rate of 3.0% for additional reference based on the social discount rate
- Present value calculations assume a long-term inflation rate of 2.5%.

The LRTP Tranche 2.1 portfolio 20-year and 40-year total revenue requirements are calculated for a range of discount rates

- The estimated capital cost of LRTP Tranche 2.1 projects is \$21.8B
- Total revenue requirement for the Tranche 2.1 portfolio is expected to be in the range of \$28.5B – \$34.7B* (7.1% discount rate)



MISO benefit cost analysis detailed results are provided for MISO Midwest Cost Allocation Zones: 20-years Lower Range

Footprint Benefits (minimum)- 20 Year NPV, 7.1%, 2024\$		(\$M)							
Benefit Metric	CAZ Allocation Method	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Total
Avoided Capacity Costs	Based on load ratio share	\$3,409	\$2,179	\$1,802	\$1,546	\$1,243	\$2,894	\$3,199	\$16,271
Capacity Savings from Reduced Losses	Based on load ratio share	\$389	\$249	\$206	\$176	\$142	\$330	\$365	\$1,857
Congestion and Fuel Savings	Derived directly from PROMOD results	\$1,366	\$2,546	\$1,689	-\$341	\$232	\$1,847	\$808	\$8,148
Energy Savings from Reduced Losses	Derived directly from PROMOD results	\$246	\$273	\$54	\$92	\$129	\$428	\$411	\$1,632
Reduced Transmission Outage Costs	Derived directly from PROMOD results	\$31	\$14	-\$34	-\$3	\$69	\$22	-\$22	\$76
Reduced Risks from Extreme Weather Impacts*	Based on load ratio share	\$82	\$53	\$44	\$37	\$30	\$70	\$77	\$394
Avoided Transmission Investment	Based on the zonal location of upgrade	\$292	\$435	\$85	\$154	\$161	\$59	\$42	\$1,228
Mitigation of Reliability Issues*	Based on location of issues	\$6,021	\$3,917	\$922	\$1,286	\$353	\$1,746	\$575	\$14,821
Decarbonization**	Based on load ratio share	\$1,515	\$968	\$801	\$687	\$552	\$1,286	\$1,421	\$7,230
Total Benefits		\$13,352	\$10,633	\$5,569	\$3,635	\$2,910	\$8,681	\$6,876	\$51,657
Total Costs		\$5,977	\$3,821	\$3,159	\$2,709	\$2,179	\$5,073	\$5,608	\$28,525
B/C		2.2	2.8	1.8	1.3	1.3	1.7	1.2	1.8

* VOLL: min=\$3,500

**Carbon Price: min=\$85

MISO benefit cost analysis detailed results are provided for MISO Midwest Cost Allocation Zones: 20-years Upper Range

Footprint Benefits (maximum)- 20 Year NPV, 7.1%, 2024\$		(\$M)							
Benefit Metric	CAZ Allocation Method	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Total
Avoided Capacity Costs	Based on load ratio share	\$3,409	\$2,179	\$1,802	\$1,546	\$1,243	\$2,894	\$3,199	\$16,271
Capacity Savings from Reduced Losses	Based on load ratio share	\$389	\$249	\$206	\$176	\$142	\$330	\$365	\$1,857
Congestion and Fuel Savings	Derived directly from PROMOD results	\$1,366	\$2,546	\$1,689	-\$341	\$232	\$1,847	\$808	\$8,148
Energy Savings from Reduced Losses	Derived directly from PROMOD results	\$246	\$273	\$54	\$92	\$129	\$428	\$411	\$1,632
Reduced Transmission Outage Costs	Derived directly from PROMOD results	\$31	\$14	-\$34	-\$3	\$69	\$22	-\$22	\$76
Reduced Risks from Extreme Weather Impacts*	Based on load ratio share	\$236	\$151	\$125	\$107	\$86	\$200	\$221	\$1,124
Avoided Transmission Investment	Based on the zonal location of upgrade	\$292	\$435	\$85	\$154	\$161	\$59	\$42	\$1,228
Mitigation of Reliability Issues*	Based on location of issues	\$17,204	\$11,190	\$2,635	\$3,675	\$1,010	\$4,988	\$1,642	\$42,345
Decarbonization**	Based on load ratio share	\$5,931	\$3,792	\$3,135	\$2,689	\$2,162	\$5,034	\$5,565	\$28,308
Total Benefits		\$29,105	\$20,828	\$9,696	\$8,096	\$5,232	\$15,802	\$12,231	\$100,990
Total Costs		\$5,977	\$3,821	\$3,159	\$2,709	\$2,179	\$5,073	\$5,608	\$28,525
B/C		4.9	5.5	3.1	3.0	2.4	3.1	2.2	3.5

* VOLL: max=\$10,000

**Carbon Price: max=\$248.67

MISO benefit cost analysis detailed results are provided for MISO Midwest Cost Allocation Zones: 40-years Lower Range

Footprint Benefits (minimum)- 40 Year NPV, 7.1%, 2024\$		(\$M)							
Benefit Metric	CAZ Allocation Method	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Total
Avoided Capacity Costs	Based on load ratio share	\$4,025	\$2,573	\$2,127	\$1,825	\$1,467	\$3,416	\$3,776	\$19,210
Capacity Savings from Reduced Losses	Based on load ratio share	\$459	\$294	\$243	\$208	\$167	\$390	\$431	\$2,193
Congestion and Fuel Savings	Derived directly from PROMOD results	\$2,856	\$3,888	\$1,000	-\$255	\$645	\$2,607	\$531	\$11,272
Energy Savings from Reduced Losses	Derived directly from PROMOD results	\$388	\$356	\$153	\$168	\$176	\$584	\$551	\$2,376
Reduced Transmission Outage Costs	Derived directly from PROMOD results	\$49	\$8	-\$26	-\$18	\$75	\$40	-\$18	\$110
Reduced Risks from Extreme Weather Impacts*	Based on load ratio share	\$117	\$75	\$62	\$53	\$43	\$99	\$110	\$557
Avoided Transmission Investment	Based on the zonal location of upgrade	\$422	\$627	\$122	\$223	\$232	\$85	\$61	\$1,773
Mitigation of Reliability Issues*	Based on location of issues	\$6,021	\$3,917	\$922	\$1,286	\$353	\$1,746	\$575	\$14,821
Decarbonization**	Based on load ratio share	\$1,877	\$1,200	\$992	\$851	\$684	\$1,593	\$1,761	\$8,960
Total Benefits		\$16,215	\$12,937	\$5,596	\$4,341	\$3,843	\$10,560	\$7,779	\$61,271
Total Costs		\$7,268	\$4,646	\$3,842	\$3,295	\$2,650	\$6,169	\$6,819	\$34,688
B/C		2.2	2.8	1.5	1.3	1.5	1.7	1.1	1.8

* VOLL: min=\$3,500

**Carbon Price: min=\$85

MISO benefit cost analysis detailed results are provided for MISO Midwest Cost Allocation Zones: 40-years Upper Range

Footprint Benefits (maximum)- 40 Year NPV, 7.1%, 2024\$		(\$M)							
Benefit Metric	CAZ Allocation Method	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Total
Avoided Capacity Costs	Based on load ratio share	\$4,025	\$2,573	\$2,127	\$1,825	\$1,467	\$3,416	\$3,776	\$19,210
Capacity Savings from Reduced Losses	Based on load ratio share	\$459	\$294	\$243	\$208	\$167	\$390	\$431	\$2,193
Congestion and Fuel Savings	Derived directly from PROMOD results	\$2,856	\$3,888	\$1,000	-\$255	\$645	\$2,607	\$531	\$11,272
Energy Savings from Reduced Losses	Derived directly from PROMOD results	\$388	\$356	\$153	\$168	\$176	\$584	\$551	\$2,376
Reduced Transmission Outage Costs	Derived directly from PROMOD results	\$49	\$8	-\$26	-\$18	\$75	\$40	-\$18	\$110
Reduced Risks from Extreme Weather Impacts*	Based on load ratio share	\$333	\$213	\$176	\$151	\$122	\$283	\$313	\$1,592
Avoided Transmission Investment	Based on the zonal location of upgrade	\$422	\$627	\$122	\$223	\$232	\$85	\$61	\$1,773
Mitigation of Reliability Issues*	Based on location of issues	\$17,204	\$11,190	\$2,635	\$3,675	\$1,010	\$4,988	\$1,642	\$42,345
Decarbonization**	Based on load ratio share	\$7,753	\$4,956	\$4,098	\$3,515	\$2,826	\$6,580	\$7,274	\$37,002
Total Benefits		\$33,490	\$24,106	\$10,528	\$9,492	\$6,720	\$18,973	\$14,563	\$117,872
Total Costs		\$7,268	\$4,646	\$3,842	\$3,295	\$2,650	\$6,169	\$6,819	\$34,688
B/C		4.6	5.2	2.7	2.9	2.5	3.1	2.1	3.4


* VOLL: max=\$10,000

**Carbon Price: max=\$248.67

Reduced Risks from Extreme Weather Impacts

The reduced risk from extreme weather impacts measures the change in the expected unserved energy (EUE) during the most severe events


- This benefit accounts for the duration and magnitude of loss of load events during extreme weather conditions (e.g., Storm Uri, 2014 and 2019 Polar Vortex)
 - Adding transmission capacity increases import/export limits, which enables access to capacity across the footprint
 - Access to a larger pool of capacity reduces the magnitude of loss of load events during extreme weather conditions
- Reduced severity of events under extreme cases are additional benefits that are not explicitly reflected in metrics like LOLE
 - The LOLE metric is a counting metric (e.g., 1 day-event), whereas EUE captures both magnitude and duration (e.g., 700 MWh)
 - LOLE is an expected value (e.g., long-term average), whereas this metric focuses on the most “severe” system conditions



Illustrative distribution of risk

The reduced risk from extreme weather impacts leverages LOLE modeling and incorporates a simplified representation of transmission constraints at the zonal level


LOLE Models: F2A & F1A, 2042



- Simplified representation of transmission constraints at the zonal level are based on seasonal capacity import (CIL) and export limits (CEL)
- The average of the worst 20% events (in terms of energy "unserved") is calculated for each case. Energy unserved includes voluntary and involuntary load shedding
- Benefits are attributed to greater EUE without Tranche 2.1
 - $EUE_{w/o\ Tranche\ 2.1} > EUE_{w/ Tranche\ 2.1}$
- Economic value is determined by multiplying the delta EUE with the value of loss of load (VOLL)
 - $(\Delta EUE_{20\%}) \times (VOLL)$


The distribution of loss of load events informs the threshold to be used for the reduced risk from extreme weather benefit

- The risk distribution shows a cluster of extreme events beyond the 2,000 MWh EUE and 4-hour duration thresholds
- The “worst” 20% EUE events (350 total) were averaged for the with/without LRTP cases
- This translates into a 1 in 5 years occurrence. The benefits are included in years 1, 5, 10, 15, and 20 of the 20-year NPV calculation



The addition of LRTP transmission reduces the system unserved energy during the most extreme events

- The reduced risk from extreme weather impacts measures the change in the expected unserved energy (EUE) during the most severe events
- A VOLL equal to 3,500 \$/MWh is used to monetize the lower end of this benefit and 10,000 \$/MWh on the upper end
- The NPV benefits of Tranche 2.1 for a 20-year period are in the range of \$394M-\$557M




Capacity Savings from Reduced Losses

Capacity Savings from Reduced Losses captures benefits from reduced system losses from the addition of transmission


- The increase in transmission capacity reduces the effective system impedance and redistributes flows from resources across the footprint to the load centers
- Less capacity is required to cover the lower system losses with the LRTP portfolio
- Losses are represented as additional reserve requirement in the incremental EGEAS resource expansion model
 - Losses are calculated from the reliability study models for season with highest reserve requirement
 - Expansion analysis is performed in combination with Avoided Capacity Cost to ensure no duplication
 - The Loss component is split out in proportion to total reserve adjustment applied in the EGEAS simulation

Similarly, lower system losses reduces the requirements for additional capacity investment, as determined by reserve requirement changes and updated regional expansions



The decrease in system losses due to the addition of LRTP transmission reduces the amount of capacity reserves that would be needed to cover system losses

- LRTP transmission lowers system losses, which reduces the need for more capacity investment and yields a 20-year present value benefit of \$1.9B*




Avoided Transmission Investment

Costs for age and condition replacement of transmission facilities are offset by rebuilds and co-location of LRTP projects along existing rights-of-way

- LRTP projects that require rebuild of existing facilities or co-location of new transmission lines with existing facilities avoids the need for future rebuild of the aging infrastructure
 - This is a conservative estimate of avoided transmission as it solely focuses on age-related transmission improvements. Other reliability projects may be avoided but are not captured in this metric.
- Candidate facilities for age and condition replacement are identified in the LRTP project scoping effort and are confirmed with relevant transmission owners
- Avoided costs are developed using exploratory level cost estimates for complete replacement of the existing facility
- Replacement projects are assumed to be in service by the 20-year study period
- Costs are distributed over 5 years prior to the assumed in service date

Avoided age and condition replacement candidates are identified in the scoping of Tranche 2.1 projects




Reuse of existing right-of-way for LRTP projects offsets the costs of age and condition replacement of aging facilities

Rebuild for capacity uprates and colocation of LRTP projects along existing facility rights-of-way avoids the need for future age and condition replacement.

Facility Replacement Summary

Voltage Class	Mileage	Cost(\$M)
345kV	208	\$667
<345kV	500	\$1,003

LRTP Tranche 2.1 portfolio avoids the need for replacement of over 700 miles of existing transmission and delivers 20-year present value benefits of \$1.2B




Congestion and Fuel Savings


Congestion and Fuel Savings measures the reduction in congestion costs and generator production costs enabled by Tranche 2.1 transmission

- Transmission allows for more efficient access to low-cost resources and reduces congestion costs with a more economical dispatch of resources
- The Congestion and Fuel Savings benefit is a measure of Adjusted Production Cost (APC) savings between the LRTP Reference Case and LRTP Change Case
 - MISO's standard production cost models do not include transmission outages apart from N-1 constraints in economic dispatch
 - This yields a conservative estimate of production cost benefits.
- LRTP Reference Case includes base MTEP transmission topology, and includes the generation portfolio identified through the Futures Series 1A
- LRTP Change Case includes everything in the LRTP Reference Case, with the addition of Tranche 2.1 transmission

APC savings will be determined by measuring the reduction of MISO Midwest APC in the LRTP Reference Case compared to MISO Midwest APC in the LRTP Change Case



L RTP Tranche 2.1 transmission projects congestion and fuel savings results



- MISO Midwest Subregion realizes \$8.1B in congestion and fuel savings over a 20-year period
- MISO Midwest Subregion realizes \$11.3B in congestion and fuel savings over a 40-year period

L RTP Tranche 2.1 transmission projects congestion and fuel savings results

Present Value	20 year PV (Millions 2024\$)		40 year PV (Millions - 2024\$)	
Discount Rate	7.1%	3.0%	7.1%	3.0%
CAZ				
1	\$1,366	\$2,236	\$2,856	\$6,876
2	\$2,546	\$3,698	\$3,888	\$7,809
3	\$1,689	\$1,932	\$1,000	-\$326
4	-\$341	-\$407	-\$255	-\$121
5	\$232	\$433	\$645	\$1,727
6	\$1,847	\$2,612	\$2,607	\$4,922
7	\$808	\$940	\$531	\$31
Total	\$8,148	\$11,443	\$11,272	\$20,916

- MISO Midwest Subregion realizes \$8.1B in congestion and fuel savings over a 20-year period
- MISO Midwest Subregion realizes \$11.3B in congestion and fuel savings over a 40-year period


NPV benefits in millions of 2024 dollars, including 2.5% annual inflation for Min/Max prices at discount rates above.
 20-year and 40-year benefits refer to projects' in-service value to 2052 and 2072, respectively.
 Emissions data interpolated between PROMOD model years 2032, 2037, and 2042; and extrapolated post-2042.

Energy Savings from Reduced Losses

New transmission reduces flows on existing wires and can reduce transmission energy loss rates


- The future resource fleet described by our members and through our stakeholder process shows new generation throughout the system, increasing the likelihood that power will be transported over longer distances
- Extra-high voltage (e.g., 345 kV, 765 kV) provides additional lower-impedance paths resulting in reduced losses that lower operating and production costs
- MISO's standard production cost models incorporate transmission losses into fixed demand profiles, so loss energy values are not included in congestion and fuel savings
- The aggregate impact of reducing loss energy may be identified by measuring the incremental impact to Adjusted Production Cost (APC) when estimated loss reductions are netted out of demand
- This metric only quantifies reductions to production costs and does not quantify capital costs
 - PROMOD performs production cost simulations and does not evaluate resource expansion
 - The Capacity Savings from Reduced Losses metric calculates effective capital cost reductions and does not include operating costs

Energy savings will be determined by measuring the additional APC savings when reduced losses are applied, beyond what is seen in the baseline Congestion and Fuel Savings



Energy Savings from Reduced Losses = Reduced Losses APC Savings – Baseline APC Savings

L RTP Tranche 2.1 transmission projects energy savings from reduced losses results



- MISO Midwest Subregion realizes \$1.6B in energy savings from reduced losses over a 20 year period
- MISO Midwest Subregion realizes \$2.4B in energy savings from reduced losses over 40 year period

L RTP Tranche 2.1 transmission projects energy savings from reduced losses results

Present Value	20 year PV (Millions 2024\$)		40 year PV (Millions - 2024\$)	
Discount Rate	7.1%	3.0%	7.1%	3.0%
CAZ				
1	\$246	\$361	\$388	\$799
2	\$273	\$376	\$356	\$626
3	\$54	\$102	\$153	\$413
4	\$92	\$143	\$168	\$379
5	\$129	\$180	\$176	\$323
6	\$428	\$598	\$584	\$1,069
7	\$411	\$571	\$551	\$993
Total	\$1,632	\$2,332	\$2,376	\$4,602


- MISO Midwest Subregion realizes \$1.6B in energy savings from reduced losses over a 20 year period
- MISO Midwest Subregion realizes \$2.3B in energy savings from reduced losses over 40 year period

Reduced Transmission Outage Costs

Transmission outages reduce operational transmission capacity and can impact congestion

- Planned and forced transmission outages are a common daily occurrence on a system-wide basis
- Transmission outages shift flows onto parallel paths, increasing loading, reducing redundancy and often increasing congestion
- MISO's standard production cost models do not include transmission outages apart from N-1 constraints in economic dispatch
 - MISO does not believe that this captures all real time congestion and reflects a conservative value
- The aggregate impact of outages may be identified by measuring the incremental impact to Adjusted Production Cost (APC) when forced and planned outages are simulated
- New transmission provides increased capacity and redundancy, and may reduce the impact of transmission outages

Reduced Transmission Outage Costs will be determined by measuring the average increase in APC savings when Transmission Outages are simulated, beyond what is seen in the baseline Congestion and Fuel Savings




$$\text{Reduced Transmission Outage Costs} = \frac{\sum_n \text{Outage Set } n \text{ APC Savings}}{N} - \text{Baseline APC Savings}$$

Reference Case: An unmodified base PROMOD case

Change Case: The same Change Case used in other value metrics, where new prospective transmission has been added to the Reference Case

MEMS FxA 20yy: MISO Economic Model Series, Future FxA, Year 20yy

L RTP Tranche 2.1 transmission projects benefits from reduced transmission outage costs results



- MISO Midwest Subregion realizes \$76M in reduced transmission outage costs over a 20 year period
- MISO Midwest Subregion realizes \$110M in reduced transmission outage costs over 40 year period

NPV benefits in millions of 2024 dollars, including 2.5% annual inflation for Min/Max prices at discount rates above.
20-year and 40-year benefits refer to projects' in-service value to 2052 and 2072, respectively.
Emissions data interpolated between PROMOD model years 2032, 2037, and 2042; and extrapolated post-2042.



L RTP Tranche 2.1 transmission projects benefits from reduced transmission outage costs results

Present Value	20 year PV (2024\$)		40 year PV (2024\$)	
Discount Rate	7.1%	3.0%	7.1%	3.0%
CAZ				
1	\$31	\$46	\$49	\$100
2	\$14	\$16	\$8	-\$2
3	-\$34	-\$40	-\$26	-\$15
4	-\$3	-\$9	-\$18	-\$56
5	\$69	\$90	\$75	\$106
6	\$22	\$34	\$40	\$91
7	-\$22	-\$27	-\$18	-\$12
Total	\$76	\$108	\$110	\$211

- MISO Midwest Subregion realizes \$76M in reduced transmission outage costs over a 20 year period
- MISO Midwest Subregion realizes \$110M in reduced transmission outage costs over 40 year period

Decarbonization

The Decarbonization metric captures LRTP's long-term benefits of reducing CO₂ emissions by enabling reliable delivery of low-cost, clean energy

- Tranche 2.1 benefit updated CO₂ costs and used the same method from Tranche 1:
 - Determine avoided emissions from LRTP economic production cost models
 - Convert emissions amounts to metric tons
 - Apply carbon costs to calculate 20- and 40-year NPV of avoided emissions


20-Year CO₂ Emissions Avoided: 127M metric tons

40-Year CO₂ Emissions Avoided: 199M metric tons

	7.1% Discount Rate		3% Discount Rate	
	Federal (Min)	MN PUC (Max)	Federal (Min)	MN PUC (Max)
2024\$/metric ton	\$85	\$249	\$85	\$249
20-Year Benefit (2024\$, M)	\$7,230	\$28,308	\$9,837	\$39,221
40-Year Benefit (2024\$, M)	\$8,960	\$37,002	\$14,925	\$65,094

LRTP Change Case illustrates the emissions reduced through enabled resources

40-Year Emissions, LRTP Reference & Tranche 2.1 Change Cases



With the price range utilized, Decarbonization benefits range from \$7B to \$65B over 40 years of project life

Range of LRTP T2.1 Decarbonization 20- & 40-Year Benefits (2024\$, M)

