



Expedited Project Review Results and Recommendation

Expedited Project Review Technical Study Task Force (EPR-TSTF)

January 6, 2026

Executive Summary




Review results and provide MISO's recommendation for EPRs which have completed mitigation discussions

- Twenty-two (22) EPRs have completed analysis and mitigation representing 3705 MW of new spot load and other reliability concerns
 - Central region representing 16 projects for review
 - West region representing 2 projects for review
 - South region representing 4 projects for review
- MISO recommends the projects move to MTEP26 Appendix A after the PAC comment period.

[ITCM] Linn County 620 MW Load Addition

ITCM: Linn County 620 MW Load Addition




| | |
|---------------------|--|
| Project # | 50775 |
| Project Name | Linn County 620 MW Load Addition |
| Project Type | Other, Load Growth |
| Project Description | Central Iowa Power Cooperative (CIPCO) on behalf of its member Linn County Rural Electric Cooperative (Linn County REC) has requested to interconnect a new 620 MW load that will be served from the Duane Arnold Energy Center (DAEC) 161 kV bus via four new radial 161 kV lines that will be owned and operated by CIPCO. To accommodate the requested load interconnection, ITC Midwest will expand the 161 kV bus at DAEC to provide 4 additional 161 kV bus positions. |
| System Need | To accommodate the requested load interconnection, 4 new 161 kV bus positions need to be added on the DAEC 161 kV bus to facilitate interconnection of the 4 new CIPCO radial 161 kV lines to the new load. No other upgrades were identified as being required to support the requested load interconnection. |
| Current Cost | \$11.26 M |
| Expected ISD | 07/01/2028 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the In-Service Date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - One (1) additional CAP was required to mitigate observed issues
- MISO coordinated with impacted neighboring entities based on the analysis results
 - We appreciate the active coordination of the impacted parties as a part of this process

51174 Corrective Action Plan (CAP)


New MTEP26 BRP project



| | |
|---------------------|---|
| Project # | 51174 |
| Project Name | MidAmerican Energy Upgrades for MTEP 50775 Linn County 620 MW Load Addition |
| Project Type | BRP |
| Project Description | Transmission line structure replacements on MidAmerican's section of the Hazleton-Arnold 345 kV line to increase the line rating. |
| System Need | The project need is to address post-contingent overloads on the Hazleton-Arnold 345 kV line identified in MISO's EPR reliability analysis of MTEP 50775 Linn County 620 MW Load Addition. |
| Current Cost | \$1.2M |
| Expected ISD | 07/01/2028 |
| Target Appendix | A in MTEP26 |

[HE] New Greensburg 138 kV Substation for New Load Addition

HE: New Greensburg 138 kV Load Addition




| | |
|---------------------|---|
| Project # | 51051 |
| Project Name | New Greensburg 138 kV Load Addition |
| Project Type | Other, Load Growth |
| Project Description | Construct a new 138 kV ring bus on the Decatur – Honda 138 kV line to serve a new large load. The new large load has a total estimated load of 50 MW. |
| System Need | A new large load has a total estimated load of 50 MW. To serve this, new 138 kV facilities are required. |
| Current Cost | \$11.1 M |
| Expected ISD | 07/01/2028 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the in-service date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - Zero (0) new TPL violations or worsened reliability issues were identified
- No neighboring entities were impacted based on the analysis results.

[HE] New Morgan County 345/69 kV Transmission Station and 69 kV Line

HE: Morgan County 345/69 kV Station and 69 kV Line




| | |
|---------------------|---|
| Project # | 51088 |
| Project Name | New Morgan County 345/69 kV Transmission Station and 69 kV Line |
| Project Type | Other, Local Reliability |
| Project Description | Construct a new 345 kV ring bus station on the Thompson – Petersburg 345 kV line between Thompson and Antioch with a 69 kV low side station. Construct a new 3.65-mile 69 kV line from the new Morgan Co transmission station to HE Mooresville tap. |
| System Need | The Hoosier 69 kV system in Morgan County is currently served from four-way 69 kV switch between DEI Plainfield South and Centerton. Bringing in a new source from the 345 kV system will substantially improve the reliability of the area and reduce difficulty managing load growth. |
| Current Cost | \$44.3 M |
| Expected ISD | 12/01/2030 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the in-service date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - Zero (0) new TPL violations or worsened reliability issues were identified
- No neighboring entities were impacted based on the analysis results.

[HE] New Jennings County 161/69 kV Transmission Station and 69 kV Line

HE: Jennings County 161/69 kV Station and 69 kV Line




| | |
|---------------------|--|
| Project # | 51089 |
| Project Name | New Jennings County 161/69 kV Transmission Station and 69 kV Line |
| Project Type | Other, Local Reliability |
| Project Description | Construct a new 161 kV ring bus on the Lawrence – Napoleon 161 kV line near Selmier Junction and a 69 kV low side ring bus. Construct new 17.9-mile 69 kV line from Jennings 69 kV station to Waynesville 69 kV station. |
| System Need | The industrial loads currently served by Selmier station cannot be effectively supported from the existing 69 kV system when the 161 kV system is unavailable. Constructing a new ring bus at this location will improve the reliability of the area and allow the existing 69 kV system to be reinforced. |
| Current Cost | \$56.9 M |
| Expected ISD | 12/01/2028 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the in-service date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - Zero (0) new TPL violations or worsened reliability issues were identified
- No neighboring entities were impacted based on the analysis results.

[HE] New Speed to Northside 138 kV Line and 138/12 kV Station

HE: Speed to Northside 138 kV Line and 138/12 kV Station



| | |
|---------------------|---|
| Project # | 51090 |
| Project Name | New Speed to Northside 138 kV Line and 138/12 kV Station |
| Project Type | Other, Load Growth |
| Project Description | Construct a new 9-mile 138 kV line from WVPA Speed 138 kV station to LGEE Northside 138 kV station. Construct a new 138/12 kV distribution station along the line to serve 15 MW new industrial load. |
| System Need | The combination of a new load request and existing constraints serving distribution customers along I-65 in Clark Co requires a new distribution station. The nearest transmission lines are blocked by the Clark Co Airport. New transmission needs to be brought into the area to serve the load. |
| Current Cost | \$27.2 M |
| Expected ISD | 3/1/2028 |
| Target Appendix | A in MTEP26 |


Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the in-service date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - Zero (0) new TPL violations or worsened reliability issues were identified
- No neighboring entities were impacted based on the analysis results.

[HE] New Gill 345 kV Station and 345 kV Lines



HE: New Gill 345kV Station and 345kV Lines




| | |
|---------------------|--|
| Project # | 51093 |
| Project Name | New Gill 345 kV Station and 345 kV Lines |
| Project Type | Other, Load Growth |
| Project Description | Approximately 1 mile south of Merom station, expand the Merom 345kV straight bus station into a 345 kV breaker-and-a-half station, located in Sullivan County, IN. |
| System Need | To serve expanding data center load up to and additional 960 MW. |
| Current Cost | \$75.3 M |
| Expected ISD | 01/01/2028 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the In-Service Date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - One (1) additional CAP was required to mitigate observed issues
- MISO coordinated with impacted neighboring entities based on the analysis results
 - We appreciate the active coordination of the impacted parties as a part of this process

50193 Corrective Action Plan (CAP)

New MTEP26 BRP project




| | |
|---------------------|---|
| Project # | 51152 |
| Project Name | New Merom to Gill 345 KV Line addition |
| Project Type | BRP |
| Project Description | Construct an additional circuit between Merom 345 kV station and Gill 345 kV station. |
| System Need | Mitigation for thermal overload of the existing Merom - Gill 345 kV circuits due to P6 scenarios in the EPR analysis. |
| Current Cost | \$2 M |
| Expected ISD | 01/01/2028 |
| Target Appendix | A in MTEP26 |

[NIPS] New Customer A 138 kV Substation for Load Addition



NIPSCO: Customer A 138 kV Substation for Load Addition




| | |
|---------------------|---|
| Project # | 51092 |
| Project Name | New Customer A 138 kV Substation for Load Addition |
| Project Type | Other, Load Growth |
| Project Description | 260 MW load is being looped into Wolf Lake to Stateline B (NIPSCO-ComEd). |
| System Need | To serve the new load addition with expedited lead time required to be 2-3 years. |
| Current Cost | \$25 M |
| Expected ISD | 12/31/2027 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the In-Service Date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - One (1) additional CAP was required to mitigate observed issues
- MISO coordinated with impacted neighboring entities based on the analysis results
 - We appreciate the active coordination of the impacted parties as a part of this process

51092 Corrective Action Plan (CAP)


New MTEP26 BRP project



| | |
|---------------------|---|
| Project # | 51124 |
| Project Name | Sheffield Substation Battery and Trip Coil Monitoring |
| Project Type | BRP |
| Project Description | Project to add monitoring to NIPSCO Sheffield 138kV substation. |
| System Need | P5 thermal observations. |
| Current Cost | \$25 K |
| Expected ISD | 12/31/2027 |
| Target Appendix | A in MTEP26 |

[SIGE] New Project Raider 345 kV Substation for New Load Addition

SIGE: Project Raider 345 kV Substation for Load Addition




| | |
|---------------------|---|
| Project # | 51079 |
| Project Name | New Project Raider Load 345 kV Substation |
| Project Type | Other, Load Growth |
| Project Description | Construct a new 345 kV breaker-and-a-half substation to serve a 600 MW load addition on the POSEY – GIBSON 345 kV line. The new station will be approximately 8 line-miles from the Posey substation. |
| System Need | A new customer has plans to construct a facility within SIGE's service territory along the Posey-Gibson line. |
| Current Cost | \$29.9 M |
| Expected ISD | 06/01/2027 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the In-Service Date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - One (1) additional CAP was required to mitigate observed issues
- MISO coordinated with impacted neighboring entities based on the analysis results
 - We appreciate the active coordination of the impacted parties as a part of this process

51079 Corrective Action Plan (CAP)


New MTEP26 BRP project



| | |
|---------------------|---|
| Project # | 51149 |
| Project Name | New Project Raider Cap Banks 69 kV |
| Project Type | BRP |
| Project Description | Adding 62.4 MVAR of cap banks at Culley 69 kV, 2 15.6 MVAR cap banks at Leonard 69 kV and 2 15.6 MVAR cap banks at Northwest 69 kV. |
| System Need | P6 low voltage observations. |
| Current Cost | \$5.1 M |
| Expected ISD | 06/01/2027 |
| Target Appendix | A in MTEP26 |

[IPL] New Antioch 345 kV Station and Load 1.2 GW Load Addition

IPL: New Antioch 345 kV Station and Load




| | |
|---------------------|---|
| Project # | 50700 |
| Project Name | New Antioch 345 kV Station and Load |
| Project Type | Other, Load Growth |
| Project Description | Construct a new 345 kV breaker-and-a-half substation on the [IPL] Thompson - [IPL] Petersburg 345 kV transmission line approximately 11 line-miles south of the IPL Thompson Substation. New customer will have distributed load off of 345 kV lines from new substation. |
| System Need | A new customer has plans to construct a facility within Indianapolis Power & Light's service territory, adjacent to the 345 kV Thompson-Petersburg transmission line. |
| Current Cost | \$68.8 M |
| Expected ISD | 11/1/2027 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the In-Service Date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - Five (5) additional CAP was required to mitigate observed issues
- MISO coordinated with impacted neighboring entities based on the analysis results
 - We appreciate the active coordination of the impacted parties as a part of this process

50768 Corrective Action Plan (CAP)


New MTEP26 BRP project



| | |
|---------------------|---|
| Project # | 50768 |
| Project Name | Upate Sunnyside Autotransformer |
| Project Type | BRP |
| Project Description | Due to FAC-008 Facility Rating Methodology, Sunnyside Autotransformer was derated to SN/SE 478 MVA. This project contains the scope necessary to return Sunnyside Autotransformer to SN 500 MVA, SE 600 MVA - allows use of operational guide 2008-S-011-C-IPL-Auto_Transformers-345_138rev1. |
| System Need | IPL Antioch and Whispering Pines EPR N-1 thermally overloaded the facility rated at 478 MVA, no greater than 575 MVA with contingency 'P71:345-345:IPL:08-16WHISPINES:16SUNNYS:345:1-16WHISPINES:08GWYNN:345'. |
| Current Cost | \$2.0 M |
| Expected ISD | 12/31/2029 |
| Target Appendix | A in MTEP26 |

50789 Corrective Action Plan (CAP)


New MTEP26 BRP project



| | |
|---------------------|--|
| Project # | 50789 |
| Project Name | Replace Guion South Autotransformer |
| Project Type | BRP |
| Project Description | Guion South autotransformer has failed asset management tests and was removed from operational service. This project replaces the autotransformer to restore to service. |
| System Need | MTEP26 EPR results indicate overloading on autotransformer. |
| Current Cost | \$11.7 M |
| Expected ISD | 12/31/2027 |
| Target Appendix | A in MTEP26 |

50790 Corrective Action Plan (CAP)


New MTEP26 BRP project



| | |
|---------------------|---|
| Project # | 50790 |
| Project Name | Expand Blue Bluff 138 kV switchyard |
| Project Type | BRP |
| Project Description | Expand currently planned 345 kV switchyard near Eagle Valley Power Plant to include a 138 kV yard and interconnection local 138 kV transmission |
| System Need | IPL EPR TPL mitigations |
| Current Cost | \$30.3 M |
| Expected ISD | 3/31/2030 |
| Target Appendix | A in MTEP26 |

50795 Corrective Action Plan (CAP)


New MTEP26 BRP project



| | |
|---------------------|---|
| Project # | 50795 |
| Project Name | Upgrade Guion - Whitestown 345-09 |
| Project Type | BRP |
| Project Description | Replace IPL equipment at Guion and Whitestown to achieve a 1526 MVA winter rating |
| System Need | IPL EPR Antioch and Whispering Pines |
| Current Cost | \$15.0 M |
| Expected ISD | 12/31/2029 |
| Target Appendix | A in MTEP26 |

51103 Corrective Action Plan (CAP)


New MTEP26 BRP project



| | |
|---------------------|---|
| Project # | 51103 |
| Project Name | New Westwood-LEAP-Hortonville 345kV Line |
| Project Type | BRP |
| Project Description | Construct new ~55mi double circuited 345kV line from Westwood to new Mechanicsburg station to Hortonville at 954 ACSS @ 200C or 4000A equivalent conductor for a rating of 2432MVA per line. Tying additional new ~10mi of double circuited 345kV line from new Mechanicsburg substation into LEAP. |
| System Need | This project is driven by recent EPR submissions and replacement for several associated rebuilds that would be required otherwise |
| Current Cost | \$250.3 M |
| Expected ISD | 6/1/2029 |
| Target Appendix | A in MTEP26 |

[LAGT] ANGIE 230/69KV SUBSTATION - 230KV LINE BREAKER ADDITIONS

LAGT: ANGIE 230/69KV SUBSTATION - 230KV LINE BREAKER ADDITIONS




| | |
|---------------------|---|
| Project # | 51063 |
| Project Name | ANGIE 230/69KV SUBSTATION - 230KV LINE BREAKER ADDITIONS |
| Project Type | Other, Local Reliability |
| Project Description | ADD 230KV LINE BREAKERS AND ASSOCIATED EQUIPMENT TO THE EXISTING 1803 ANGIE 230/69KV SUBSTATION |
| System Need | INCREASE RELIABILITY OF THE ANGIE DELIVERY POINT BY ADDING ADDITIONAL INTERRUPTING DEVICES |
| Current Cost | \$1.9M |
| Expected ISD | 12/31/2027 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the In-Service Date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - No impact to the system was found

[LAGT] HOLTON 115/69KV SUBSTATION-115KV LINE BREAKER AND 69KV BUS TIE BREAKER ADDITIONS

LAGT: HOLTON 115/69KV SUBSTATION - 115KV LINE BREAKER AND 69KV BUS TIE BREAKER ADDITIONS




| | |
|---------------------|---|
| Project # | 51064 |
| Project Name | HOLTON 115/69KV SUBSTATION - 115KV LINE BREAKER AND 69KV BUS TIE BREAKER ADDITIONS |
| Project Type | Other, Local Reliability |
| Project Description | ADD 115KV LINE BREAKERS, A 69KV BUS TIE BREAKER, AND ASSOCIATED EQUIPMENT TO THE EXISTING 1803 HOLTON 115/69KV SUBSTATION |
| System Need | INCREASE RELIABILITY OF THE HOLTON DELIVERY POINT BY ADDING ADDITIONAL INTERRUPTING DEVICES. |
| Current Cost | \$2.9M |
| Expected ISD | 6/1/2028 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the In-Service Date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - No impact to the system was found

[LAGT] TALISHEEK 230KV LINE BREAKER ADDITIONS AND 69KV BUS TIE BREAKER ADDITION

LAGT: TALISHEEK 230KV LINE BREAKER ADDITIONS AND 69KV BUS TIE BREAKER ADDITION




| | |
|---------------------|---|
| Project # | 51065 |
| Project Name | TALISHEEK 230KV LINE BREAKER ADDITIONS AND 69KV BUS TIE BREAKER ADDITION |
| Project Type | Other, Local Reliability |
| Project Description | ADD 230V LINE BREAKERS, A 69KV BUS TIE BREAKER, AND ASSOCIATED EQUIPMENT TO THE EXISTING 1803 TALISHEEK 230/69KV SUBSTATION |
| System Need | INCREASE RELIABILITY OF THE TALISHEEK DELIVERY POINT BY ADDING ADDITIONAL INTERRUPTING DEVICES. |
| Current Cost | \$4.7M |
| Expected ISD | 6/1/2029 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the In-Service Date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - No impact to the system was found

[LAGT] EAST MANDEVILLE 230/69KV SUBSTATION

LAGT: EAST MANDEVILLE 230/69KV SUBSTATION



| | |
|---------------------|---|
| Project # | 51070 |
| Project Name | EAST MANDEVILLE 230/69KV SUBSTATION |
| Project Type | Other, Local Reliability |
| Project Description | ENGINEER, PROCURE, AND CONSTRUCT A NEW 230/69KV SUBSTATION TO SERVE WST'S MANDEVILLE AND LACOMBE STATIONS. THIS SUBSTATION REMOVES THE NEED FOR THE MANDEVILLE MEDIUM VOLTAGE DELIVERY POINT AND PROVIDES A NEW 230KV SOURCE TO THE SOUTH SIDE OF 1803/WSTE'S SYSTEM. |
| System Need | THE EXISTING MANDEVILLE TO LACOMBE 69KV LINE IS CURRENTLY OPERATED AT 34.5KV AND HAS REACHED ITS CAPACITY. THE 1803/WSTE LONG TERM PLANS FOR THIS AREA IS TO CONVERT THE MANDEVILLE AND LACOMBE STATIONS TO 69KV OPERATION AND EXTEND A 69KV LINE FROM THE NEW EAST MANDEVILLE SUBSTATION THROUGH LACOMBE AND TO HICKORY. |
| Current Cost | \$16.9M |
| Expected ISD | 12/1/2028 |
| Target Appendix | A in MTEP26 |

Models, Reliability Analysis, and Neighbor Coordination

- The EPR was applied to all applicable MTEP models based on the In-Service Date. Models were posted for submitting TO review prior to analysis.
- MISO performed TPL-001-5.1 no-harm analysis utilizing n-1 and n-1-1 contingencies centered around the point of interconnection of the EPR
 - Results were posted for impacted entity feedback
 - No impact to the system was found

Questions?
